

AENOR Product Certificate

Electric distribution cables



075/000143

AENOR, Spanish Association for Standardization and Certification, certifies that the organization

ALCOBRE CONDUTORES ELECTRICOS, S.A.

registered office Av D. MANUEL I - ZONA INDUSTRIAL DE OVAR
3880 OVAR (Distrito De Aveiro - Portugal)

supplies Cable of rated voltage 0,6 /1 kv. XLPE insulated. Aluminium conductor.

in compliance with UNE 21030-1:2014 (HD 626S1:1996)

Designation RZ
Trade Mark ALCOBRE
Restriction 2 x 16 Al; 2 x 25 Al; 4 x 16 Al; 4 x 25 Al; 4 x 50 Al; 3 x 95/50 Al; 3 x 150/95 Al;
1 x 25 Al/54,6 Alm; 1 x 50 Al/54,6 Alm; 3 x 25 Al/29,5 Alm; 3 x 25 Al/54,6 Alm;
3 x 50 Al/29,5 Alm; 3 x 50 Al/54,6 Alm; 3 x 95 Al/54,6 Alm; 3 x 150 Al/80 Alm;

Production site ZONA INDUSTRIAL DE OVAR / APDO. 30 3880 OVAR (Portugal)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 75.01.

This certificate supersedes 075/000143, dated 2012-10-22

First issued on 2012-10-22
Modified on 2016-08-16
Validity date 2021-08-16

The image shows the AENOR logo and a signature. The signature is in blue ink and is written over the AENOR logo. Below the signature, the text 'Asociación Española de Normalización y Certificación' is visible.
Avelino BRITO
Chief Executive Officer

AENOR Asociación Española de
Normalización y Certificación

Génova, 6. 28004 Madrid. España
Tel. 902 102 201 – www.aenor.es